

Blue/CN-Panel/D

No Connection X	Cable Label	Cable Class	Cable Style	Circuit Name(s)	Circuit ID & Load / Source Location - or -	
					Panel or Device	
1	1E-S01	CL2	22-4	1E-S01, Refrigeration Alarm (Signal) 1E-P01, Refrigeration Alarm (Power)	Refrig@Lobby Fridge	
2	1E-S02	CL2	22-2	1E-S02, Door	1E-S02	
3	1E-S03	CL2	22-4	1E-S03, Smoke Detector (Signal) 1E-P03, Smoke Detector (Power)	Smoke@Foot of Lower Stairs	
4	1E-S04	CL2	22-4	1E-S04, Motion Detector (Signal) 1E-P04, Motion Detector (Power) 1E-S05, Motion Detector (Trouble)	Motion@Lobby	
5	1F-A01/02	CL2	18-4	1F-A01, Alarm Speaker 1F-A02, Alarm Strobe	@Theater	
6	1G-A01	CL2	18-4	1G-A01, Alarm Speaker 1G-A02, Alarm Strobe	@Lounge Sitting Area	
7	1G-A04	CL2	18-2	1G-A04, Door Strike	1G-A04 Lounge Entry	
8	1G-A12	CL2	22-4 (S)	1G-A12, Inside Strobe Pilot 1G-A19, Smoke Power Pilot	White/CN-Panel/1	
9	1G-A13	CL2	14-4	1G-A13, Blue Panel LV Power Supply 1G-A35, Single-point Common	White/CN-Panel/2	
10	1G-A14	CL2	22-4 (S)	1G-A14, Blue Panel LV Power Sense	White/CN-Panel/2	
11	1G-A16	CL2	18-2	1G-A16, 24 Vdc Power (Line)	White/CN-Panel/2	
12	1G-A17	CL2	22-2	1G-A17, Floor Heat Setback - BR 2/3 Bath	White/CN-Panel/2	
13	1G-S03	CL2	22-4	1G-S03, Smoke Detector (Signal) 1G-P03, Smoke Detector (Power)	Smoke@Lounge Sitting Area	
14	1G-S05	CL2	22-2	1G-S05, Shop Door	1G-S05 Lounge Entry	
15	1G-S06	CL2	22-2	1G-S06, Water Sensor Chain	1G-S06 Lounge Bar	
Change	1G-S07	CL2	22-4	1G-S07, Motion Detector (Signal) 1G-P07, Motion Detector (Power)	Motion@Lounge Sitting Area	
17	1G-S08/09	CL2	22-6	1G-S08, Window (L) 1G-S09, Window (R)	1G-S08 Lounge Sitting Area 1G-S09 Lounge Sitting Area	
18	1G-S16>20	CL2	22-8	1G-S16, Changing Room A: Door 1G-S17, Changing Room B: Door 1G-S18, BR 2/3 Bath Doors (2) 1G-S20, BR 2/3 Bath: Motion (2G-S13)	White/CN-Panel/2	
19	1H-S0/506	CL2	22-4	1H-S05, Window (L) 1H-S06, Window (R)	1H-S05 Changing Rooms Hall 1H-S06 Changing Rooms Hall	
20	1H-S03	CL2	22-2	1H-S03, Water Sensor Chain	1H-S03 Changing Room A	
21	1H-S04	CL2	22-2	1H-S04, Door	1H-S04 Changing Room A	
22	1H-S07	CL2	22-2	1H-S07, Window	1H-S07 Changing Room B	
23	1H-S08	CL2	22-2	1H-S08, Door	1H-S08 Changing Room B	
24	1K-A03	CL2	22-4	1K-A03, Overhead Door Actuate	1K-A03 Shop	
25	1K-A04	CL2	18-2	1K-A04, Air Filter Enable	1K-A04 Shop	
26	1K-A05/06	CL2	18-4	1K-A05, Alarm Speaker 1K-A06, Alarm Strobe	@Shop	

Blue/CN-Panel/D

No Connection X	Cable Label	Cable Class	Cable Style	Circuit Name(s)	Circuit ID & Load / Source Location	
					- or - Panel or Device	
27	1K-A08	CL2	18-4	1K-A08, Gas Heater Override	1K-A08	Shop
28	1K-S04	CL2	22-2	1K-S04, Overhead Door	1K-S04	Shop
29	1K-S06	CL2	22-4	1K-S06, Smoke Detector (Signal) 1K-P06, Smoke Detector (Power)	Smoke@Shop	
30	1K-S07	CL2	22-6	1K-S07, CO Detector (Signal) 1K-P07, CO Detector (Power) 1K-S11, CO Detector (Trouble)	CO@Shop	
31	1K-S08	CL2	22-6	1K-S08, Combustible Gas Detector (Signal) 1K-P08, Combustible Gas Detector (Power) 1K-S12, Combustible Gas Detector (Trouble)	Gas@Shop	
32	1K-S09	CL2	22-4	1K-S09, Motion Detector (Signal) 1K-P09, Motion Detector (Power)	Motion@Shop	
33	2D-A02	CL2	18-4	2D-A02, Alarm Strobe 2D-A06, Alarm Speaker	@Kitchen	
34	2F-A03/04	CL2	18-4	2F-A03, Alarm Speaker 2F-A04, Alarm Strobe	@Stairway Landing	
					@BR 3	
35	2F-A06	CL2	18-2	2F-A06, Security Keypad Contact (04)	Elk Keypad 2F	
36	2F-A10	CL2	22-12	2F-A10, #Call-Button-Dim-L 2F-A11, #Auto-Close-L 2F-A12, #All-Close-L 2F-A13, #Lower-Open-L 2F-A14, #Lower-Close-L 2F-A15, #Upper-Open-L 2F-A16, #Upper-Close-L	Silver/CN-Panel	
37	2F-A17	CL2	22-12	2F-A17, Lo-Pressure-L 2F-A18, Trouble-L 2F-A19, Lower-Door-Closed-L 2F-A20, Upper-Door-Closed-L	Silver/CN-Panel	
38	2F-S03	CL2	22-2	2F-S03, Main Door	2F-S03	BR 3
39	2F-S05/06	CL2	22-4	2F-S05, Window (L) 2F-S06, Window (R)	2F-S05	BR 3
					2F-S06	BR 3
40	2F-S07	CL2	22-8	2F-S07, Smoke Detector (Signal) 2F-P07, Smoke Detector (Power)	Smoke@BR 3 Hall	
41	2F-S11	CL2	22-4	2F-S11, Smoke Detector (Signal) 2F-P11, Smoke Detector (Power)	Smoke@BR 3	
42	2F-S12	CL2	22-4	2F-S12, CO Detector (Signal) 2F-P12, CO Detector (Power) 2F-S16, CO Detector (Trouble)	CO@BR 3	
43	2G-A02	CL2	18-2	2G-A02, Security Keypad Contact (10)	Elk Keypad 2G	
44	2G-A04	CL2	22-2	2G-A04, Floor Heat Setback	2G-A04	BR 2/3 Bath
45	2G-A05	CL2	18-4	2G-A05, Alarm Strobe 2G-A06, Alarm Speaker	@BR 2	
46	2G-S01	CL2	22-4	2G-S01, SE Window	2G-S01	BR 2
47	2G-S02	CL2	22-4	2G-S02, NE Window	2G-S02	BR 2

Blue/CN-Panel/DNo
Connection

X

Cable Label	Cable Class	Cable Style	Circuit Name(s)	Circuit ID & Load / Source Location	
				- or - Panel or Device	
48	2G-S03/04	CL2	22-4 2G-S03, N Window (L) 2G-S04, N Window (R)	2G-S03 BR 2 2G-S04 BR 2	
49	2G-S05	CL2	22-4 2G-S05, Smoke Detector (Signal) 2G-P05, Smoke Detector (Power)	Smoke@BR 2	
50	2G-S06	CL2	22-4 2G-S06, CO Detector (Signal) 2G-P06, CO Detector (Power) 2G-S14, CO Detector (Trouble)	CO@BR 2	
51	2G-S08	CL2	22-2 2G-S08, Bathroom Door	2G-S08 BR 2 Hall	
52	2G-S09	CL2	22-2 2G-S09, Door	2G-S09 BR 2 Hall	
53	2G-S11	CL2	22-4 2G-S11, Water Sensor Chain	2G-S11 BR 2/3 Bath	
54	2G-S12	CL2	22-2 2G-S12, Bathroom Door	2G-S12 BR 3	
55	2G-S13	CL2	22-4 2G-S13, Motion (Signal) 2G-P13, Motion (Power)	Motion@BR 2/3 Bath	
56	1F-C14	UTP	Cat 5 (M1) 1F-C14, M1G Data Bus (Blue to Green)	Green/CN-Panel	
57	1G-A03	UTP	Cat 5 (M1) 1G-A03, Security Keypad Data (03)	Elk Keypad 1G	
58	1G-C11	UTP	Cat 5e 1G-C11, Alarm Speaker Line Level Drive	White/CN-Panel/1	
59	1G-C16	UTP	Cat 5 (M1) 1G-C16, M1G Data Bus (Orange to Blue)	Orange/CN-Panel/L	
60	1K-A01	UTP	Cat 5 (M1) 1K-A01, Security Keypad Data (04)	Elk Keypad 1K	
61	2F-A05	UTP	Cat 5 (M1) 2F-A05, Security Keypad Data (07)	Elk Keypad 2F	
62	2G-A01	UTP	Cat 5 (M1) 2G-A01, Security Keypad Data (09)	Elk Keypad 2G	
63	1G-33	Power	14-2 1G-33, Blue/CN-Panel Outlet	Blue/CB-Panel Blue/GP-Panel Blue/CN-Panel/U	