

Red/CN-Panel/D

No Connection X	Cable Label	Cable Class	Cable Style	Circuit Name(s)	Circuit ID & Load / Source Location	
					- or - Panel or Device	
1	1A-A03	CL2	18-4	1A-A03, Alarm Strobe 1A-A04, Alarm Speaker	@BR 5 Alcove	
2	1A-S01	CL2	22-6	1A-S01, Window (R) 1A-S14, Window Intrusion (R)	1A-S01 BR 5 1A-S14 BR 5	
3	1A-S03	CL2	22-2	1A-S03, Bathroom Door	1A-S03 BR 5	
4	1A-S07/15	CL2	22-6	1A-S07, Window Sash 1A-S15, Window Intrusion	1A-S07 BR 4/5 Bath 1A-S15 BR 4/5 Bath	
5	1A-S08	CL2	22-4	1A-S08, Motion Detector (Signal) 1A-P08, Motion Detector (Power)	Motion@BR 4/5 Bath	
6	1A-S10	CL2	22-2	1A-S10, Water Sensor Chain	1A-S10 BR 4/5 Bath Toilet	
7	1A-S11/12	CL2	22-6	1A-S11, Smoke Detector (Signal) 1A-S12, CO Detector (Signal) 1A-P11, Smoke Detector (Power) 1A-P12, CO Detector (Power) 1A-S16, CO Detector (Trouble)	Smoke@BR 5 Alcove CO@BR 5	
8	1B-A03	CL2	18-4	1B-A03, Alarm Strobe 1B-A04, Alarm Speaker	@BR 4	
9	1B-S01/11	CL2	22-6	1B-S01, Desk Window 1B-S11, Window Intrusion	1B-S01 BR 4 Desk 1B-S11 BR 4 Desk	
10	1B-S02	CL2	22-2	1B-S02, Bathroom Door	1B-S02 BR 4	
Change	1B-S04	CL2	22-6	1B-S04, Smoke Detector (Signal) 1B-S05, CO Detector (Signal) 1B-P04, Smoke Detector (Power) 1B-P05, CO Detector (Power) 1B-S07, CO Detector (Trouble)	Smoke@BR 4 CO@BR 4	
12	1B-S10	CL2	22-4	1B-S09, Window (L) 1B-S10, Window Intrusion (L)	1B-S09 BR 4 1B-S10 BR 4	
13	1C-A01	CL2	18-4	1C-A01, Alarm Speaker 1C-A17, Alarm Strobe	@Long Hall	
14	1C-A03	CL2	22-4 (S)	1C-A03, Inside Strobe Pilot 1C-A07, Smoke Power Pilot	White/CN-Panel/1	
15	1C-A04	CL2	14-4	1C-A04, Panel LV Power Supply Input 1C-A19, Single-point Common	White/CN-Panel/2	
16	1C-A05	CL2	22-4 (S)	1C-A05, Panel LV Power Supply Sense	White/CN-Panel/2	
17	1C-A11	CL2	22-6	1C-A11, Radon Blower Trouble 1C-P05, Radon Blower Current OK (Power)	Red/GP-Panel	
18	1C-A15	CL2	18-2	1C-A15, Master Closet Safe Power	White/CN-Panel/6	
19	1C-S03	CL2	22-2	1C-S03, Door	1C-S03 Red Utility Closet	
Change	1C-S06	CL2	22-4	1C-S06, Motion Detector (Signal) 1C-P06, Motion Detector (Power)	Motion@Long Hall	
21	1C-S07/08	CL2	22-6	1C-S07, Smoke Detector (Signal) 1C-S08, CO Detector (Signal) 1C-P07, Smoke Detector (Power) 1C-P08, CO Detector (Power) 1C-S10, CO Detector (Trouble)	Smoke@Long Hall CO@Long Hall	

Red/CN-Panel/D

No Connection X	Cable Label	Cable Class	Cable Style	Circuit Name(s)	Circuit ID & Load / Source Location	
					- or - Panel or Device	
22	1C-S09	CL2	22-10	1C-S09, BR 4/5 Bath: Doors (1A-S03/1B-S02) 1C-S11, Master Bath Doors (2B-S02 / 2A-S08) 1C-S14, BR 4/5 Bath: Motion (1A-S08) 1C-S15, Master Bath: Motion (1A-S07) 1C-S13, Master Closet Door	White/CN-Panel/2	
23	1D-S01	CL2	22-2	1D-S01, Door (S)	1D-S01	Fitness Room
24	1D-S02	CL2	22-2	1D-S02, Door (N)	1D-S02	Fitness Room
25	1D-S03	CL2	22-4	1D-S03, Smoke Detector (Signal) 1D-P03, Smoke Detector (Power)	Smoke@Fitness Room	
26	2A-A01	CL2	22-4	2A-A01, Wall Safe Power 2A-A09, Safe Door	2A-A01	Master Closet 2 2A-A09 Master Closet 2
27	2A-A03	CL2	18-4	2A-A03, Alarm Strobe 2A-A11, Alarm Speaker	@Master BR	
28	2A-A07	CL2	18-4	2A-A07, Alarm Speaker 2A-A10, Alarm Strobe	@Master BR Hall	
29	2A-S01	CL2	22-2	2A-S01, Window	2A-S01	
30	2A-S02>04	CL2	22-4	2A-S02, Window Sash (L) 2A-S03, Window Sash (C) 2A-S04, Window Sash (R)	2A-S02	Master BR 2A-S03 Master BR 2A-S04 Master BR
31	2A-S05	CL2	22-4	2A-S05, Window Intrusion	2A-S05	Master BR
32	2A-S06/13	CL2	22-2	2A-S06, Deck Door	2A-S06	Master BR Foyer
33	2A-S08	CL2	22-2	2A-S08, Bathroom Door	2A-S08	Master BR
34	2A-S10	CL2	22-2	2A-S10, Door	2A-S10	Master Closet 1
35	2A-S12	CL2	22-2	2A-S12, Window	2A-S12	Master Closet 2
36	2A-S14	CL2	22-4	2A-S14, Smoke Detector (Signal) 2A-P14, Smoke Detector (Power)	Smoke@Master Closet 1	
37	2A-S15	CL2	22-4	2A-S15, Smoke Detector (Signal) 2A-P15, Smoke Detector (Power)	Smoke@Master BR	
38	2A-S16	CL2	22-4	2A-S16, CO Detector (Signal) 2A-P16, CO Detector (Power) 2A-S11, CO Detector (Trouble)	CO@Master BR	
39	2A-S17	CL2	22-4	2A-S17, Smoke Detector (Signal) 2A-P17, Smoke Detector (Power)	Smoke@Master BR Hall	
40	2B-A01	CL2	22-8	2B-A01, Tub Control	2B-A01	Master Bath
41	2B-S01	CL2	22-2	2B-S01, Window	2B-S01	Master Bath
42	2B-S02	CL2	22-2	2B-S02, Wet Bar Door	2B-S02	Master Bath
43	2B-S03	CL2	22-2	2B-S03, Wet Bar Door	2B-S03	Study
44	2B-S04	CL2	22-2	2B-S04, Window	2B-S04	Study
45	2B-S07	CL2	22-4	2B-S07, Motion Detector (Signal) 2B-P07, Motion Detector (Power)	Motion@Master Bath	
46	2B-S10	CL2	22-4	2B-S10, Smoke Detector (Signal) 2B-P10, Smoke Detector (Power)	Smoke@Study	

Red/CN-Panel/D

No Connection X	Cable Label	Cable Class	Cable Style	Circuit Name(s)	Circuit ID & Load / Source Location	
					- or -	Panel or Device
47	2B-S11	CL2	22-2	2B-S11, Water Sensor Chain	2B-S11	Study Wet Bar
48	2B-S12	CL2	22-2	2B-S12, Window	2B-S12	Master Toilet
49	2C-S06	CL2	22-4	2C-S06, Glass Break Detector (Signal) 2C-P06, Glass Break Detector (Power)	Glass@Great Room	
50	2C-S10	CL2	22-4	2C-S10, Smoke Detector (Signal) 2C-P10, Smoke Detector (Power)	Smoke@Great Room	
Change	2C-S12	CL2	22-4	2C-S12, Motion Detector (Signal) 2C-P12, Motion Detector (Power)	Motion@Great Room	
52	2M-A03	CL2	22-8	2M-A03, Hot Tub Control	2M-A03	Hot Tub Area
53	4A-S10	CL2	22-6	4A-S10, Heat Rate-Of-Rise (Signal) 4A-P10, Heat Rate-Of-Rise (Power)	Heat Rate@Attic - ^ Upper Level	
54	4A-S11	CL2	22-6	4A-S11, Heat Rate-Of-Rise (Signal) 4A-P11, Heat Rate-Of-Rise (Power)	Heat Rate@Attic - ^ Laundry Rm	
55	4A-S12	CL2	22-6	4A-S12, Heat Rate-Of-Rise (Signal) 4A-P12, Heat Rate-Of-Rise (Power)	Heat Rate@Attic - ^ Master BR	
56	1A-A02	UTP	Cat 5 (M1)	1A-A02, Security Keypad Data (11)	Elk Keypad 1A	
57	1B-A02	UTP	Cat 5 (M1)	1B-A02, Security Keypad Data (10)	Elk Keypad 1B	
58	1C-C06	UTP	Cat 5e	1C-C06, Alarm Audio Line Level Drive	White/CN-Panel/1	
59	1C-C13	UTP	Cat 5 (M1)	1C-C13, M1G Data Bus (Green to Red)	Green/CN-Panel	
60	2A-A04	UTP	Cat 5 (M1)	2A-A04, Security Keypad Data (06)	Elk Keypad 2A	
X	2B-A02	UTP	Cat 5e	2B-A02, Automation Receiver (Provisions Only)	2B-A02	Study Wet Bar
X	2B-C11	UTP	Cat 6	2B-C11, spare UTP@Cable Port 2B-06	2B-C11	Study (Cable Port 2B-06)
63	1C-26	Power	14-2	1C-26, "Red" Controller Panels	Red/CB-Panel	
					Red/XL-Dim/1	
					Red/XL-Dim/2	
					Red/XL-HVRB	
					Red/XL-FSCB	
					Red/CN-Panel/U	