

Silver/CN-Panel

| No Connection X | Cable Label | Cable Class | Cable Style | Circuit Name(s) | Circuit ID & Load / Source Location | |
|------------------------------------|-------------|-------------|-------------|---|-------------------------------------|-------------------------|
| | | | | | - or - | Panel or Device |
| 1 | 1M-A01 | CL2 | 22-6 | 1M-A01, Top Door Button - Call | | Button@Lower Stairway ↑ |
| 2 | 1M-A02 | CL2 | 22-6 | 1M-A02, Bottom Door Button | | Button@Lower Stairway ↓ |
| 3 | 2F-A02 | CL2 | 22-6 | 2F-A02, Stairway Door Button | | Button@Stairway Landing |
| 4 | 2F-A10 | CL2 | 22-12 | 2F-A10, #Call-Button-Dim-L 2F-A11, #Auto-Close-L 2F-A12, #All-Close-L 2F-A13, #Lower-Open-L 2F-A14, #Lower-Close-L 2F-A15, #Upper-Open-L 2F-A16, #Upper-Close-L | | Blue/CN-Panel/D |
| 5 | 2F-A17 | CL2 | 22-12 | 2F-A17, Lo-Pressure-L 2F-A18, Trouble-L 2F-A19, Lower-Door-Closed-L 2F-A20, Upper-Door-Closed-L | | Blue/CN-Panel/D |
| X | 2F-S02 | CL2 | 22-2 | 2F-S02, Stairway Door Closed | 2F-S02 | Stairway Landing |
| Change | 2K-A01 | CL2 | 22-6 | 2K-A01, Bottom Door Button | | Button@Upper Stairs ↓ |
| 8 | 2K-A02 | CL2 | 22-6 | 2K-A02, Top Door Button - Call | | Button@Upper Stairway ↑ |
| Change | 3A-A01 | CL2 | 22-6 | 3A-A01, Stairway Door Button | | Button@Lakeside Rm |
| X | 3A-S60 | CL2 | 22-2 | 3A-S60, Stairway Door Closed | | Orange/CN-Panel/L |
| 11 | 2F-12 | Power | 14-2 | 2F-12, Silver/CN-Panel Outlet (UPS Secondary) | | White/GP-Panel/1 |