

<b>M1 Gold Main Module</b>		Count in Panel: <b>1</b>	Elk Products: ELK-M1GCB	
#1	M1 Gold Main Module	Security & Automation	Item Tag #: 0062	Installation Status: Landed
<b>M1 16 Zone Input Module</b>		Count in Panel: <b>3</b>	Elk Products: ELK-M1XIN	
#1	"Input Expander 1-1 (11)"	Security & Automation	Item Tag #: 0178	Installation Status: Landed
#2	"Input Expander 1-2 (12)"	Security & Automation	Item Tag #: 0241	Installation Status: Landed
<b>M1 Output Expander 8 Voltage / 8 Relay</b>		Count in Panel: <b>4</b>	Elk Products: ELK-M1XOVR	
#1	"Output Expander CN/1 (02)"	Security & Automation	Item Tag #: 0399	Installation Status: Landed
<b>M1 Output Relay Board</b>		Count in Panel: <b>5</b>	Elk Products: ELK-M1RB	
#1	M1 Output Relay Board	Security & Automation	Item Tag #: 0055	Installation Status: Landed
<b>M1 Ethernet Interface Module</b>		Count in Panel: <b>6</b>	Elk Products: ELK-M1XEP	
#1	M1 Ethernet Interface Module	LAN	Item Tag #: 0269	Installation Status: Landed
<b>M1 Data Bus Hub</b>		Count in Panel: <b>7</b>	Elk Products: ELK-M1DBH	
#1	"M1 Data Bus Hub 1"	Security & Automation	Item Tag #: 0238	Installation Status: Landed
<b>M1 Siren/Voice Driver</b>		Count in Panel: <b>8</b>	Elk Products: ELK-120	
#2	"Alarm Speaker Driver, Outside"	Security & Automation	Item Tag #: 0177	Installation Status: Landed
<b>Power Dist Module, 12Vdc, 250ma</b>		Count in Panel: <b>9</b>	Elk Products: ELK-PD9	
#1	"General 12 Vdc Power Distribution"	Security & Automation	Item Tag #: 0602	Installation Status: Landed
<b>Power Dist Module, 12Vdc, 400ma</b>		Count in Panel: <b>11</b>	Elk Products: ELK-PD9HC	
#1	"Inside Strobe 12 Vdc Power Distribution"	Security & Automation	Item Tag #: 0658	Installation Status: Landed
#2	"Outside Strobe +12 Vdc Power Distribution"	Security & Automation	Item Tag #: 0701	Installation Status: Landed
<b>M1 Audio Amplifier</b>		Count in Panel: <b>12</b>	Elk Products: ELK-800	
#1	"Inside Alarm Speaker Amplifier #1"	Security & Automation	Item Tag #: 0113	Installation Status: Landed
<b>Transformer, 70v Audio, 4Ω, 10W</b>		Count in Panel: <b>13</b>	Edcor: WS15-70	
#1	"Alarm Speaker 70v Step-up Transformer"	Security & Automation	Item Tag #: 1176	Installation Status: -----

Spare Cable Group		Count in Panel: 14		
#1	Spare Cable Group	(uncommitted)	Item Tag #: NA	Installation Status:
Power Connection Point		Count in Panel: 15	Field Splice	
#1	"12 Vdc Power Connection Point (UPS)"	Security & Automation	Item Tag #: NA	Installation Status: ----
Outlet, Duplex (15A)		Count in Panel: 16	(Part TBD)	
#1	"Line Power"	Power, Passing	Item Tag #: 0303	Installation Status:
9-Zone Combiner / Indicator		Count in Panel: 18	JTB: 1006-1	
#1	"Trouble Indicator, Mech Room"	Security & Automation	Item Tag #: 1060	Installation Status: Landed
#2	"Zone Combiner"	Security & Automation	Item Tag #: 1121	Installation Status: Landed
9-Zone Isolated Combiner		Count in Panel: 19	JTB: 1006-2	
#1	"Down Spout Tamper Detector"	Down Spout Alarm	Item Tag #: 0335	Installation Status: Landed
Resistor, 8Ω, 3W		Count in Panel: 20	JTB (Part TBD)	
#1	"External Alarm Speaker Leg A Dummy 8Ω Load"	Security & Automation	Item Tag #: 1178	Installation Status: ----