

Relay, DPDT, 24 Vdc (Plug-In)		Count in Panel: 5	Potter & Brumfield: KUP-11D15-24	
#1	"Kitchen: Cooking Area Recessed DPDT"	Emerg Control (EC)	Item Tag #: 0057	Installation Status: On Hand
#2	"Garage: Parking Area Lights DPDT"	Emerg Control (EC)	Item Tag #: 0058	Installation Status: On Hand
#3	"Upper Bar: Recessed Lights DPDT"	Emerg Control (EC)	Item Tag #: 0059	Installation Status: On Hand
#4	"Lakeside Room Recessed Lights DPDT"	Emerg Control (EC)	Item Tag #: 0060	Installation Status: On Hand
#5	"Upper Bath: Recessed Lights DPDT"	Emerg Control (EC)	Item Tag #: 0112	Installation Status: On Hand
Relay, 3PDT, 120 Vac (Plug-In)		Count in Panel: 6	Potter & Brumfield: KUP-14D15-120	
#1	"Roof Tape Power Monitor Relay"	Power, Monitoring	Item Tag #: 1145	Installation Status: ----
Power Supply, 12 Vdc, 10W DIN		Count in Panel: 7	Lambda: DSP10-12	
#1	"Roof Tape Power Indicator 12 Vdc Supply"	Power, Monitoring	Item Tag #: 1153	Installation Status: Landed
Power Supply, 24 Vdc, 100W DIN		Count in Panel: 8	Lambda: DSP100-24	
#2	"LED Lighting 24 Vdc Power, Kitchen: Vaulted Ceiling"	Power, Conversion	Item Tag #: 1097	Installation Status: On Hand
Power Supply, 24 Vdc, 240W DIN		Count in Panel: 9	Lambda: DLP240-24	
#1	"LED Lighting 24 Vdc Power, Upper Stairs: Tread"	Power, Conversion	Item Tag #: 0206	Installation Status: On Hand
Spare Cable Group		Count in Panel: 10		
#1	"Spare 120 Vac Cable(s)"	(uncommitted)	Item Tag #: n/a	Installation Status: ----
Fan & Sensor Kit, Cabinet		Count in Panel: 11	JTB: 1010-3	
#1	"Enclosure Vent Fan & Temp Sensor"	Energy Control (NC)	Item Tag #: 1134	Installation Status: ----
Dimmer, Type 1, Dual 4A		Count in Panel: 12	JTB: 1002	
#1	"Dimmer (Kitchen: Vaulted Ceiling Outer & Inner)"	Power, Switching	Item Tag #: 1077	Installation Status: Landed
Dimmer, Single 10A		Count in Panel: 13	JTB: 1004	
#1	"Dimmer 10A (Upper Stairs: Tread)"	Power, Switching	Item Tag #: 1104	Installation Status: ----